

CERTIFICATE OF ANALYSIS

Sunridge Petroleum Distribution · 8800 Pipeline Road, Houston, TX 77002

COA #COA-2026-002193

Issued: April 28, 2026 at 11:18 am CDT

PRODUCER

Sunridge Petroleum Distribution
8800 Pipeline Road
Houston
TX 77002

SHIP TO

Coastal Logistics Group
1500 Harbor Way
Galveston, TX 77550
Attn: Fleet Operations

Product Ultra-Low-Sulfur Diesel (No. 2-D S15) **BOL #** BOL-911284
Sample # #41773 **Technician** M. Castillo

RESULT: PASS

Test Results

Test Method	Standard	Result	Unit	Min	Max	Status
Sulfur Content (UV Fluorescence)	ASTM D5453	8.4	mg/kg	—	15.0	PASS
Cetane Index (Calculated)	ASTM D4737	47.2	—	40.0	—	PASS
Flash Point (Pensky-Martens)	ASTM D93	64	°C	52	—	PASS
Density @ 15°C	ASTM D4052	0.842	g/mL	0.820	0.860	PASS
Distillation — 90% Recovered	ASTM D86	328	°C	—	338	PASS
Cloud Point	ASTM D2500	-12	°C	—	-8	PASS
Water and Sediment	ASTM D2709	0.02	%vol	—	0.05	PASS
Lubricity (HFRR Wear Scar)	ASTM D6079	405	um	—	520	PASS

Specifications per ASTM D975 Grade No. 2-D S15 (ultra-low-sulfur, ≤ 15 ppm). Sample drawn from terminal storage at point of loading.

AUTHORIZED BY

Sample Q. Manager

Quality Assurance Manager

Generated: April 28, 2026 at 11:18 am CDT

CERTIFICATE OF ANALYSIS

Sunridge Petroleum Distribution · 8800 Pipeline Road, Houston, TX 77002

This Certificate of Analysis represents results from samples drawn from the source identified above. Results apply to the lot or batch as tested. This document was generated automatically by COA Creator and reflects lab results entered at the time of issue.